

INDIAN INSTITUTE OF SCIENCE EDUCATION AND RESEARCH THIRUVANANTHAPURAM (IISERTVM) (Govt. of India, Ministry of H.R.D)

Рн: 0471-2597454 Fax:0471-2597427

EMAIL: PURCHASESTORES@JISERTVM.AC.IN

CET CAMPUS, KULATHUR, ENGINEERING COLLEGE.P.O
THIRUVANANTHAPURAM 695016,
KERALA, INDIA.

Date: 08th April 2015

INVITATION TO TENDER(IND)

No: IISER/PUR/5598/15
Due Date: 21st April 2015 [4PM]

Date of Opening: 22nd April 2015 [3PM]

Dear Sirs.

Sub: Supply of Numeric 600VA UPS.

We invite Sealed Tenders for the following items:

Sl	Item/ Description	Otv
No:		Qty
1.	600VA UPS [Specifications as per Annexure I]	10 Nos

Please quote your lowest rate and shortest delivery period as per the following terms. Your offer in sealed cover **SUPERSCRIBING TENDER NUMBER AND DUE DATE** shall reach us on or before the due date and time.

Payment

: Within 30 days after supply and installation/Net 30 days /LC. No advance payment will be made by IISERTVM.

Delivery

Warranty

: To be delivered at our stores (Free delivery). If import, mention

Ex-works/FCA/CIP terms with clear breakup charges.

: For a minimum period of one year from the date of supply

and installation

Taxes & Duties

: Indicate taxes and duties. We are exempted for customs duty

under 51/96 notification and Excise duty under 10/97

notifications.

Discount

: Indicate, if any.

Delivery Schedule

: Required Immediately. Indicate your schedule

Validity of quote

: 60 days

Thanking You,

Yours Faithfully

K. BHASKARA RAO
Deputy Registrar
[Purchase & Stores]

P.S: CATALOGUE/LEAFLET FEATURING ALL TECHNICAL SPECS/INFORMATION OF THE PRODUCT QUOTED SHALL ACCOMPANY THE OFFER.

IISER-TVM, Govt. of India, Ministry of H.R.D.

N.B. PLEASE ATTEND THE TENDER OPENING WITH AUTHORIZATION LETTER.

Specifications

- ➤ Input Voltage -140-300V AC
- ➤ Nominal Frequency 50Hz
- ➤ Output Voltage -230V
- ➤ Capacity -600VA
- > Waveform -Quasi Sine Wave
- ➤ Battery Type -Sealed Lead Acid Maintenance Free
- ➤ Battery Capacity 12V, 7AH
- ➤ Backup time 20 Minutes
- LED Mains on, Main Fail, Battery Low, Fault Overload
- Alarms Mains Fail, Battery Low, Overload
- > Protection Under/Over voltage, Spike/Surge protection
- Others Automatic Voltage Regulator, EMI/RFI suppression, Line interactive
- ➤ Warranty 2 Years

K. BHASKARA RAO Deputy Registrar [Purchase & Stores]