



**INDIAN INSTITUTE OF SCIENCE EDUCATION AND
RESEARCH THIRUVANANTHAPURAM (IISERTVM)
(Govt. of India, Ministry of H.R.D)**

CET CAMPUS, KULATHUR, ENGINEERING COLLEGE.P.O
THIRUVANANTHAPURAM 695016,
KERALA, INDIA.

PH: 0471-2597454
FAX:0471-2597427

EMAIL: PURCHASESTORES@IISERTVM.AC.IN

Date: 23rd July 2015

INVITATION TO TENDER(IND)

No: IISER/PUR/5842/15

Due Date: 04th August 2015 [4PM]

Date of Opening: 05th August 2015 [3PM]

Dear Sirs,

Sub: Supply of **Automatic Power Transfer Switch.**

We invite Sealed Tenders for the following items:

Sl No:	Item/ Description	Qty
1.	Supply and installation of Automatic Power Transfer switch [Specifications as per Annexure I]	1 No

Please quote your lowest rate and shortest delivery period as per the following terms. Your offer in sealed cover **SUPERSCRIBING TENDER NUMBER AND DUE DATE** shall reach us on or before the due date and time.

- Payment** : Within 30 days after supply and installation/Net 30 days /LC. **No advance payment will be made by IISERTVM.**
- Delivery** : To be delivered at our stores (Free delivery). If import, mention Ex-works/FCA/CIP terms with clear breakup charges.
- Taxes & Duties** : Indicate taxes and duties. We are exempted for customs duty under 51/96 notification and Excise duty under 10/97 notifications.
- Discount** : Indicate, if any.
- Delivery Schedule** : Required Immediately. Indicate your schedule
- Validity of quote** : 60 days

Thanking You,

Yours Faithfully


K.BHASKARA RAO
Deputy Registrar
[Purchase & Stores]


P.S. (1) OUR PREVIOUS TENDER OF EVEN NO. DATED 18TH JUNE 2015 (DUE DT 30TH JUNE 2015) STANDS CANCELLED AND THIS IS A RETENDER.

(2) CATALOGUE/LEAFLET FEATURING ALL TECHNICAL SPECS/INFORMATION OF THE PRODUCT QUOTED SHALL ACCOMPANY THE OFFER.

IISER-TVM, Govt. of India, Ministry of H.R.D.

Specifications for Automatic Power Transfer Switch

Input	:	Two AC Power
Output	:	One AC Power
Working	:	If the primary AC power fails, the unit should automatically switch to the alternative power source.
Output voltage	:	230V
Maximum Total output current	:	16A
Output Connections	:	Minimum one IEC 320C19
Input Voltage	:	230V
Input frequency	:	47-63 Hz
Input Connections	:	Two IEC -320C20
Maximum input line current	:	20A
Regulatory requirements	:	cUL Listed, CE, EN 55022 Class A, FCC Part 15 Class A, UL Listed
Compliance	:	RoHS, REACH
Power Cables	:	One IEC-320 C19, Two IEC-320 C20
Warranty	:	2 Years
Others	:	Rack mountable, Digital display of current drawn, Remote management via Web, SNMP


K. BHASKARA RAO
Deputy Registrar
[Purchase & Stores]