

**QUOTATION DOCUMENT**

---

Name of Bidder :


---

Sealed Quotations are invited on behalf of the Director, IISER TVM and will be received in the Office of the Project Engineer cum Estate Officer(I/C), IISER TVM Vithura campus from agencies having similar experience in the relevant field for the following works at IISER TVM Vithura Campus, Thiruvananthapuram District, Kerala.

Name of Work	Estimated Cost	EMD
<i>Dedicated earthing for Lab 3113 CSB, IISER TVM campus, Thiruvananthapuram</i>	<b>Rs. 41,440/-</b>	<b>₹ 830/-</b>

The offer for the work shall remain open for acceptance for a period of 30 days from the date of opening of quotation and the work shall be completed within 30 days from the date of receipt of work order.

The filled & duly signed Quotation documents and Schedule of Quantities (SOQ) should always be placed in sealed cloth lined cover super-scribing the name of work will be received in the Office of the Project Engineer cum Estate Officer(I/C), IISER TVM, Maruthamala P.O., Thiruvananthapuram-695551 Up to 06-04-2022 at 15.30 Hrs and will be opened by authorized officer of IISER TVM on 06-04-2022 at 16.00 Hrs in the presence of tenderers or their representatives who would like to be present. In case of representatives the Authorization letter should be produced to within the tender opening.



Project Engineer cum Estate Officer(I/C)  
IISER TVM

## GENERAL TERMS & CONDITIONS

1. The bidder should attach valid class B electrical contractor license, GST registration details, pan details at the time of bidding.
2. Bidders are advised to go through the entire general terms and conditions of this tender carefully. The prices should be quoted in the format provided in Schedule of Quantities.
3. Bidders shall furnish the Earnest Money Deposit through SBI collect / Crossed Demand Draft in favour of IISER Thiruvananthapuram issued by any Nationalized Bank and endorsed by the Bank concerned at the disposal of the "IISER Thiruvananthapuram" for the work.
4. Quotations without EMD will be summarily rejected.
5. Rates quoted should be inclusive of GST and other charges if any. No extra shall be paid.
6. The materials used shall be strictly as per specification and tested for its quality at site.
7. The work shall be made at IISER TVM campus, Maruthamala PO Vithura.
8. Payment 100% within 30days after completing the work.
9. The earth enhancing material for the earth station will be non-corrosive, thermally conductive, potential to permissible limits, superior fault conduction capacity, non toxic , weather resisitance and capacble of achieveing ohmic value less than one as mentioned in item no. 2.0. of SOA .
10. Rates quoted by the Contractor in item rate tender in figures shall be accurately filled in MS excel spread sheet available in IISER website along with the document, so that there is no discrepancy between the rates written in figures and words. However, if a discrepancy is found, it will be dealt as follows:-
  - i. In the case of any tender where unit rate of any item/items appears unrealistic, such tender will be considered as unbalanced and in case the tenderer is unable to provide satisfactory explanation, such a tender is liable to be disqualified and rejected.
  - ii. All documents of the tender are to be read in conjunction with each other and rates quoted accordingly by the tenderer.

Validate

Print

Help

### Item Rate BoQ

Tender Inviting Authority: Project Engineer cum Estate Officer(I/C), IISER Thiruvananthapuram

Name of Work: Dedicated earthing for Lab 3113 CSB, IISER TVM campus, Thiruvananthapuram

Contract No: 04712778039/8036

Name of the Bidder/  
Bidding Firm /  
Company :

#### PRICE SCHEDULE

(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only )

NUMBER # Sl. No.	TEXT # Item Description	NUMBER # Quantity	TEXT # Units	NUMBER # Rate in Figures to be entered by the bidder in Rs. p	NUMBER # TOTAL AMOUNT With Taxes Rs. P	TEXT # TOTAL AMOUNT In Words
1.0	Earthing with copper earth plate 600 mm X 600 mm X 3 mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe of 2.7 metre long etc. (but without charcoal/ coke and salt ) as required.	1.00	Each		0.00	INR Zero Only
2.0	Providing and filling of earth enhancing material in the earth station as mentioned in item no. 1.0 and as required.	100.00	kg		0.00	INR Zero Only
<b>Total in Figures</b>					0.00	INR Zero Only
<b>Quoted Rate in Words</b>					INR Zero Only	