



**INDIAN INSTITUTE OF SCIENCE EDUCATION AND  
RESEARCH THIRUVANANTHAPURAM [IISERTVM]**

PH.-0471 2778019,  
EMAIL: [purchasestores@iisertvm.ac.in](mailto:purchasestores@iisertvm.ac.in)

MARUTHAMALA.P.O VITHURA. P.O  
THIRUVANANTHAPURAM 695551,  
KERALA, INDIA  
GST No.32AAAJI0299R1ZS

IISER/PUR/2009/SD/BS/TSM/SC/SP/20-21

13 Apr 2021

**CORRIGENDUM**

**Sub: Supply Installation and commissioning of 9 fume hoods, ducting system and three flammable storage cabinet in Lab 4203 and Lab 3211 in the chemical science block and Lab 2111 in Physical science block at IISER campus Vithura**

**Ref: Tender Enquiry No. 2021\_IISRT\_624004\_1**

1. The technical specifications of above referred tender is amended as under:

| Sl No | Clause   | Specification   |
|-------|--|---|
| 1     | Type of Fume Hood  | 8 fume-hoods should be CAV (for non AC room) type and one fume-hood should be VAV type (for AC room)  |
| 2     | Details of Flammable Storage Cabinet   | total three Flammable storage cabinet having capacity 45 gallon/170Litres is required.  |
| 3     | Quantity/Cluster of PP+FRP centrifugal Blower  | Two 5 HP for lab no 4203 and lab no 3211. One 1 HP for lab no 2111.   |
| 4     | Quantity of PP+FRP ducting   | Exact length of PP+FRP ducting is not known, approximately 46 M, 51 M and 50 ft for lab 4203, 211 and 2111 respectively). The vendor may provide the price per square ft. |
| 5     | General - Electrical   | Power supply will be provided within one meter of the position of the fume hood. The internal wiring, piping etc., does not form part of our scope.                       |
| 6     | General - Civil  | Water supply and the waste line will be provided within one meter of the fume-hood's position.  |
|       | General- the tentative layout of each lab indicating the location of each fume hood. | As per Enclosed layout's  |

Bidders are request to note the above amendments and submit their bids accordingly.


2. The important dates are also revised as under:

Due date for submission of bids: 28 Apr 2021 (03.00 P.M)


Due date for opening of technical Bids: 29 Apr 2021 (03.30 P.M)

Thanking You,

Yours Faithfully


  
13/04/21  
Deputy Registrar (P&S)

Lab 2111



*Handwritten signature or initials*

Lab 4203



2.50M WD COF

- NOTE**
1. TWO SIDE TABLE 1+1 UNITS TO BE DISCARDEC
  2. SIDE TABLE 4 UNITS TO BE SHIFTED TO OFFICE
  3. SIDE TABLE 2 UNITS TO BE DISCARDED.

| Revision No. | Date of Issue | Details |
|--------------|---------------|---------|
|              |               |         |
|              |               |         |


| Client | Name | Dat |
|--------|------|-----|
|        |      |     |

| Consultant | Designated | Date |
|------------|------------|------|
|            |            |      |
|            |            |      |
|            |            |      |
|            |            |      |

| Scale  | Title                                   | Project No.  |
|--------|---|--------------|
| N.T.S. | PROPOSED LAYOUT OF LAB FOR DR. SOUMEN I | LAB No. 4203 |



A blue handwritten signature or mark is present in the bottom right corner of the drawing.